

```

%Lizeta Gkogka 2012
%LCOH and Investment cost for distribution system. T=90C-140C

%Based on email conversation with Lizeta Gkogk (May, 2016), lower
%temperatures than 90C are okay whereas temperatures above 140C mean a
%change in the piping material.

%Input 1: lentgh. pipe length (m) of network. This is the distance that our
%pipes are required to travel, in order to cover heat demand in a specific
%city/university

%Input 2. Qmax. Set the demand Qmax you are covering (MW). This is the peak
load
%at your design temperature.

%Input 3. Tnetwork. Set the temperature of the network. You can choose
between 90C and
%140C, basically choose between 90,95,100,...,140C. (keep step=5)

%input 4: elprice. set the price of electricity (for pumping needs), $/kWh

%input 5: maintenance. set the maintenance cost. $/Mwh delivered

%input 6: discount, payback. set discount rate and payback time for LCOH
calculations (this is
%just for future reference)

%input 7:If you want, set yearly load (MWh). The simplest thing you can do is
just let it scale
%it according to Cornell.

```

```

function [minIC...
, minannualmillions...
, doptimum...
, numberoptimum...
, Cdist...
, PumpIC...
, BldgCost...
, SystemSetup...
, ShaftP...
, Energy...
, pumpingcost...
, PC...
, LCOheat...
, LCOheatnominator...
, LCOheatdenominator...
, PeakFuelCost...
, PeakBoilerCost...
, TotBldgCost1...
, TotBldgCost2...
, BldgCost1...
, BldgCost2]= distcostFcn(Proportionlplant...
, length_road...
, MQgeo...

```

```

, Qmax...
, mf...
, Tps0...
, elprice...
, discount...
, payback...
, MassFlowRate...
, BranchDistance...
, res_bldgs...
, res_units...
, com_bldgs...
, com_units...
, detached...
, attached...
, bldg2_4...
, bldg5_19...
, bldg20_49...
, bldg50_plus...
, SqFtUnit...
, PeakUnitDmnd...
, RoadCoverage...% Proportion of roads
in town with main distribution piping
, Tsr0...
, Tss0...
, HXAreaCentral...
, U0...
, Tpr0...
, networkservice...
, GasPrice...
, PeakMW)

%Retrofit options: %Option 1: assume indirect system - i.e. no central
plant, ind'l bldg. HX, etc...
                    %Option 2: assume centralized system - i.e. centralized
heat exchange plant, dist. water straight to bldg. radiators...
                    %Else assume no cost for heat exchangers, controls,
pumps, branch lines, etc.

% length of the piping system
% length of roads*portion of roads that need pipes
length = length_road*RoadCoverage;

% density of ?? (kg/m^3)
density=943;

%4-16in diameter (2-8in radius) of pipes. Basically this allows selection
%relatively to mass flow.
r=linspace(2,8,13);

%thresshold for pipe diameter calculation

%find the minimum radius, when installing one pipe. From excel:
diameter(maximum) =
%1.5197*massflow^0.427. When radius reaches 6in (diameter=12in),

```

```

%extrapolate linearly to find the according diameter.

% gravity constant
g=9.81;

% specific weight (N/m^3)
spweight=density*g;

%assume 60% efficiency for pump;
efficiency=0.6;

%Re>10^6 ..turbulent flow
fmoody=0.027; % friction factor for moody diagram
velocity=zeros(365,13);
hf=zeros(365,13);
DP=zeros(365,13);
PP=zeros(365,13);
ShaftP=zeros(365,13); % shaft power
Energy=zeros(13,1);
rinminimum=zeros(20,1);

%This model allows installation up to 10 pipes. We can add more-if
%reasonable.

%first find the maximum flow
mfmax=0;
for i=1:365
    if mfmax<mf(i)
        mfmax=mf(i);
    end
end

mfmax0 = mfmax;

%If total system flow exceeds cap (ten 16" pipes) then build multiple
separate networks rather than one giant network
if mfmax > 1670;
    mfmax = 1670;
    %mass flow will be divided amongst networks
    mf = mf*(1670/mfmax0);
else
    mfmax = mfmax0;
end

for i=1:10
    if mfmax>(106.4647*i)
        rinminimum(i)=0.5*(5.5726+0.062183*((1/i)*mfmax));
    else
        rinminimum(i)=0.5*(1.5197*((1/i)*mfmax)^0.427);
    end
end
end

```

```

pipenumber=zeros(13,1);
for k=1:13
    for i=1:365
        for h=1:10
            %find the number of pipes you should install
            %if the selected radius is above the limiting factor, then put
            %h number of pipes.

            if r(k)>rinminimum(h)
                %install h pipes
                velocity(i,k)=mf(i)/(h*density*pi()*((r(k)*0.0254)^2));

hf(i,k)=fmoody*(length/((r(k)*0.0254)*2))*(velocity(i,k)^2)/(2*g);
                DP(i,k)=spweight*hf(i,k);
                PP(i,k)=DP(i,k)*mf(i)/density;
                %Now find the total loss (all pipes)
                ShaftP(i,k)=h*PP(i,k)/efficiency;
                %we have daily data so the output ShaftP(W) must be
multiplied by 24 to
                %derive the daily consumption (Wh)
                Energy(k)=Energy(k)+24*ShaftP(i,k);
                %keep the number of pipes you have selected to install
                pipenumber(k)=h;

                %now stop the for-loop since you don't want to install more
than needed
                break
            end

            %ok, now for very small pipe diameter, when you have very high
mass
            %flow, you should take into account that you can't install for
example 2in
            %radius..
            if r(k)<rinminimum(10)
                %    %report as infinite power needed
                Energy(k)=10^16;
                ShaftP(i,k)=10^16;
            end
        end % end for loop over h
    end % end for loop over i
end % end for loop over k

MWH=Energy/1000000;
%total pumping cost
pumpingcost=MWH*elprice*1000;

PC=zeros(1,13);

for j=1:13
    PC(j)=pumpingcost(j)/MQgeo;
end

```

```

%pumping investment cost
%assume that cost varies proportionally to power output (kW)
%for 800kW purchased cost 30,000$==>with f=3.5: 120000$. No further data for
%pumping cost function with capacity in Perry's, so assume linear scaling
up/down

%find maximum power needed by the pump.
Shaftmax=zeros(13,1);
Shaftmax=max(ShaftP(:,1:13));

Pneeded=Shaftmax;
%calculate investment cost of pump according to its capacity. scale up/down.
PumpIC=(Pneeded/800000)*120000;

%distribution cost variations according to pipe diameter (corrected)
%y=92.435x + 284.77
%Based on email with Lizeta Gkogka (May, 2016) the use of the new
%development values for retrofitting is okay because paving costs are
%accounted for elsewhere or would be over accounted for now
Cdist=zeros(13,1);
for i=1:13
    if pipenumber(i)==1
        %install one pipe
        %Cdist(i)=length*(79.72*(r(i)*2) + 191.65); %Assume supply and return
line same trench
        %Cdist(i)=length*(55.72*(r(i)*2) + 171.9); %Assume single loop (no
return pipe)
        Cdist(i)=length*(75.82*(r(i)*2) + 83.06); %Assume new development (no
road cutting, repaving, etc.)
        %Cdist(i)=length*(51.81*(r(i)*2) + 63.31); %Assume BEST CASE
development (single pipe, no road cutting, no repaving, etc.)
    elseif pipenumber(i)<6
        %that's just a simplification. We are not really sure how many times we
are going to account for paving costs
        %Cdist(i)=(1+(pipenumber(i)-1)*(1-0.2876))*length*(79.72*(r(i)*2) +
191.65); %Supply and return pipe
        %Cdist(i)=(1+(pipenumber(i)-1)*(1-0.2876))*length*(55.72*(r(i)*2) +
171.9); %Assume single loop (no return pipe)
        Cdist(i)=(1+(pipenumber(i)-1)*(1-0.2876))*length*(75.82*(r(i)*2) +
83.06); %Assume new development (no road cutting, repaving, etc.)
        %Cdist(i)=(1+(pipenumber(i)-1)*(1-0.2876))*length*(51.81*(r(i)*2) +
63.31); %Assume BEST CASE development (single pipe, no road cutting, no
repaving, etc.)
    else
        %Cdist(i)=(2+(pipenumber(i)-2)*(1-0.2876))*length*(79.72*(r(i)*2) +
191.65); %Supply and return pipe
        %Cdist(i)=(2+(pipenumber(i)-2)*(1-0.2876))*length*(55.72*(r(i)*2) +
171.9); %Assume single loop (no return pipe)
        Cdist(i)=(2+(pipenumber(i)-2)*(1-0.2876))*length*(75.82*(r(i)*2) +
83.06); %Assume new development (no road cutting, repaving, etc.)
        %Cdist(i)=(2+(pipenumber(i)-2)*(1-0.2876))*length*(51.81*(r(i)*2) +
63.31); %Assume BEST CASE development (single pipe, no road cutting, no
repaving, etc.)
    end
end
end

```

```

%Now find costs of service lines, heat exchangers, interior equipment, etc.

BldgCost1 = zeros(13,1);
BldgCost2 = zeros(13,1);

Loopin = Tsr0;           %Return temperature of heating loop (secondary fluid
from radiators)
Loopout = Tss0;         %Supply temperature of heating loop (secondary fluid
to radiators)

%Figure cost of service lines to buildings

BldgCount = [detached; attached; bldg2_4; bldg5_19; bldg20_49; bldg50_plus;
com_bldgs];           %Number of buildings of each size category
UnitsPerBldg = [1 2 3 13 35 65 com_units/com_bldgs];
%Assumed number units per bldg category (detached, attached, 2-4, 5-19, 20-
49, 50+)
PeakLoads = (PeakUnitDmnd*1055/3600)*UnitsPerBldg;
%Estimated peak load per building [Watts thermal]
ReqKgs = (PeakLoads/(4.2*(Loopout-Loopin)))/1000;
%Estimated peak massflow per building [kgs]
ReqSrvcDiam = 1.5197*(ReqKgs.^0.427);
%Calculated diameter of req'd service pipes [inches] (from piping
spreadsheet)
CostSrvcPerMeter = 130.89*ReqSrvcDiam + 52.348;
%Estimated cost of service lines for each building type [$ /m]
TotSrvcLineCost = CostSrvcPerMeter*BranchDistance*BldgCount;
%Estimated total cost of service lines for community [$]

%Figure cost of building heat exchangers (for retrofit option 1)

GFin = Tps0;           %Design supply temperature of network
(geofluid from well)
GFout = Tpr0;         %Design return temperature of network (geofluid to well)

DeltT10 = GFin - Loopout;
DeltT20 = GFout - Loopin;
LMTD0 = (DeltT10 - DeltT20)/log(DeltT10/DeltT20);           %Log mean temperature
difference for HX
HXAream = PeakLoads/(U0*LMTD0);           %Req'd area of HX for
buildings [m2]
HXArea = HXAream*10.764;           %Req'd HX area [ft2]
CostPerFt = 222.36*HXArea.^-0.379;           %Cost of HX [$ /ft2]
HXCos = HXArea.*CostPerFt;           %Cost of HX's for
each building category [$]
OtherCost = [2000 2000 3000 5000 5000 8000 2000*com_units/com_bldgs];
%Estimated cost of add'l building components (hot water retrofit, booster
pump, etc. - Rafferty 2001)
NetBldgCost = HXCos + OtherCost;
TotBldgCost1 = NetBldgCost*BldgCount;           %Total cost of
building equipment for retrofit option 1 (heat HX's, pumps, hot water
retrofit, booster pump (large bldg only))

```

```

TotBldgCost2 = OtherCost*BldgCount; %Estimated cost of
building equipment for retrofit option 2 (booster pumps (large bldg only),
hot water retrofit)

%Figure cost of interior equipment (per unit)
UnitCost = 3000; %Estimated cost of interior heating
coil, controls, piping, etc. (Rafferty 2001)

%Peaking equipment calculations
PeakMBTUpperHr = PeakMW*3412141/1000;
%Excess peak MBTU/hr req'd
PeakBoilerCost0 = max(0, ((PeakMBTUpperHr)*50)^0.95); %Cost
of peak boilers (Estimated from CEE 2001)
PeakBoilerCost(1:13,1) = PeakBoilerCost0;

PeakFuelCost = max(0, (((PeakMBTUpperHr*30)/0.8)/1020)*GasPrice);
%Annual cost of peaking fuel in 2011 dollars

%Figure cost if central plant is used (retrofit option 2)
HXAreaCentralft = Proportionlplant*HXAreaCentral*10.764; %Size of
central plant HX

%CentralPlantCost = 49117*log(Qmax)+83651; %Assumed cost of
central heat exchange facility (Rafferty 1996) [$/MWth] (for retrofit option
2)
CentralPlantCost = 34290*log(Qmax)+74987+(222.36*HXAreaCentralft^-
0.379)*HXAreaCentralft; %Assumed cost of central HX facility with new HX
sizes...

BldgCost1(1:13,1) = TotSrvLineCost*Proportionlplant +
(res_units+com_units)*UnitCost*Proportionlplant +
TotBldgCost1*Proportionlplant;
BldgCost2(1:13,1) = TotSrvLineCost*Proportionlplant +
(res_units+com_units)*UnitCost*Proportionlplant +
TotBldgCost2*Proportionlplant + CentralPlantCost;

BldgCost = zeros(13,1);

if DelT10<=0
    SystemSetup = {'IMPOSSIBLE'};
elseif DelT20<=0
    SystemSetup = {'IMPOSSIBLE'};
elseif BldgCost1(1,1) > BldgCost2(1,1);
    BldgCost = BldgCost2;
    SystemSetup = {'Indirect'};
elseif BldgCost1(1,1) < BldgCost2(1,1);
    BldgCost = BldgCost1;
    SystemSetup = {'Centralized'};
else BldgCost = BldgCost1;
    SystemSetup = {'Either'};
end

%now find the total investment cost, consisting of pumps and piping costs.
totalcost=zeros(13,1);

```

```

totalcost(:,1)=Cdist(:,1)+PumpIC(:,1)+BldgCost(:,1)+PeakBoilerCost(:,1);

% totalcost = totalcost*1.25;

LCOheat=zeros(13,1);
LCOheatnominator=zeros(13,payback);
LCOheatdenominator=zeros(13,payback);
dolperkwheat=zeros(13,1);
centsperkwheat=zeros(13,1);

for t=1:payback
    LCOheatnominator(:,t) = (totalcost + pumpingcost + networkservice*length
+ PeakFuelCost)/((1+discount)^t);
    LCOheatdenominator(:,t) = MQgeo/((1+discount)^t);
end

for i=1:13
    LCOheat(i) = sum(LCOheatnominator(i,:))/sum(LCOheatdenominator(i,:));
    dolperkwth = LCOheat./1000;

    % for j=1:13
    %
    % LCOheat(j)=0;
    %
    %
LCOheatnominator(j)=(totalcost(j)+(maintenance+PC(j))*MQgeo)/(1+discount);
    % LCOheatdenominator(j)=(MQgeo/((1+discount)));
    %
    %     for i=2:payback
    %
LCOheatnominator(j)=LCOheatnominator(j)+((maintenance+PC(j))*MQgeo/(1+discount
)^i));
    %
LCOheatdenominator(j)=LCOheatdenominator(j)+(MQgeo/((1+discount)^i));
    %     end
    %
    % LCOheat(j)=LCOheatnominator(j)/LCOheatdenominator(j);
    % dolperkwheat(j)=LCOheat(j)/1000;
    % centsperkwheat(j)=dolperkwheat(j)*100;
    %
    %
    % end

%Optimization loop optimized for minimum LCOH
minLCOH = 10000;
for j=1:13;
    if dolperkwth(j)<minLCOH;
        minLCOH=dolperkwth(j);
        minIC=totalcost(j);
        minoperating=(networkservice*length+pumpingcost(j))+PeakFuelCost;
        doptimum=2*r(j);
        numberoptimum=pipenumber(j);
    end
end

```

```

%minIC = minIC*0.75;

%optimization loop. set an arbitrary value for minimum investment cost.
%At! optimization only according to Investment cost
% minIC=10000000000000;
%   for i=1:13
%       if minIC>totalcost(i)
%           minIC=totalcost(i);
%           minoperating=(maintenance+PC(i));
%           doptimum=2*r(i);
%           lcohoptimum=dolperkwhheat(i);
%           numberoptimum=pipenumber(i);
%       else
%           end
%       end

minannualmillions=(minoperating)/1000000;

end % end for loop over is

```